

## ADDENDUM NO. 2

---

**DATE:** May 6, 2020  
**FROM:** City of Seminole Public Works  
**TO:** All Plan Holders  
**SUBJECT:** ADDENDUM NO. 2 to the bidding documents for the  
*City of Seminole - Waterfront Park Restroom Project*

---

### BID DOCUMENTS

#### 1.1 DESCRIPTION; Questions from Pre-bid Meeting

- a. Plans show recessed lights. How will recessed lights work with trusses? **Ref revised sheet E-1 L2 light fixture has been revised to a surface mounted fixture**
- b. Plans show H14 hurricane clips. Contractor questioned the use of these clips. Stated they were no longer available. **It is the correct tie down clip and I was just on line and was able to order this product.**
- c. What are the specs for the Tongue and Groove? **Ref revised sheet A-5 1x6 T. G. is pine (paint grade) clg planking**
- d. What is the trim detail for the columns? **Ref revised sheet A-8 with added detail B/a-8 added**
- e. What is the finish color for the louver vents? **Louvers to match color of existing wall as close as possible.**
- f. What is the brand and model for fixtures? **Ref sheets E-1 & P-2 schedules for brand and model #**
- g. What is the brand and model for high/low drinking fountain? **Ref revised sheet P-1 Schedule for add fixture EWC-1 info**
- h. Can we use CPVC or PEX piping in place of Copper? **PEX piping is the preferred alternative to Copper piping.**
- i. Do you have the geotechnical report? **Geotechnical report was added to web site and Demand Star**

Clarification question about pavilions; This project does not include the building of any pavilions.

**END OF ADDENDUM NO. 2**