

ADDENDUM NO. 4

To the Technical Specifications for:

Fire Station 29 HVAC Replacement

City of Seminole

1. **BID DATE: NO CHANGE**

Thursday, March 02, 2023 @ 11:30 A.M.

2. **RESPONSE TO QUESTIONS**

- Is Test & Balance limited strictly to the new unit(s) being installed? Or are all air devices (supply, return, and fresh air) required to be balanced as well? If so, please supply documents sufficient to accomplish this.
 - Only the new units.
- Does unit heater need to match or exceed existing kW performance?
 - No, this building is on a Variable Air Volume system

CITY OF SEMINOLE

February 21, 2023